

PROPOSED FUEL DISPENSING ISLAND

- a. Construct a concrete service island and install one electric diesel fuel dispensing pump and one electric gasoline dispensing pump. Pumps to be pedestal type similar to McMaster-Carr pump no. 4379P8.
- b. Island to be located a minimum of 15 feet from the motor pool building to allow service from either side.
- c. Install a 12,000 liter underground gasoline storage tank with piping to gasoline pump at service island.
- d. Re-pipe fuel lines from existing underground diesel fuel storage tank to diesel pump at service island.
- e. Install electrical power lines to dispensing pumps.

